

WATER QUALITY CONTROL PS.AT

June 28, 2001

Item 11 Doc 6

990 East Mission Road P. O. Box 2290 Fallbrook, California 92088-2290 (760) 728-1125 Fax (760) 728-6029

Board of Directors: Milt Davies Bob Francis Arne Gunnarsson Bert Hayden Mary McNeil

Staff: Keith Lewinger General Manager

Jos. F. Jackson Chief Engineer

Larry E. Byers Administrative Services

Robert H. James Legal Counsel

Ruth Allen Board Secretary California Regional Water Quality Control Board
Attention POTW Compliance Division
San Diego Region
9771 Clairemont Mesa Boulevard, Suite B
San Diego, California 92124-1331

NPDES MONTHLY MONITORING REPORT FOR BOARD ORDER NUMBER 2000-12.

Enclosed please find the May 2001 Monthly Monitoring Report for Board Order Number 2000-12.

Also enclosed find the City of Oceanside's May 2001, Monthly Receiving Water Report as requested.

On May 13, the secondary sludge clarifier sludge blanket came up and released excessive suspended solids resulting in a violation of our daily suspended solids concentration limitation. Please note that the monthly average was not exceeded.

Corrective action:

Problems with secondary settling appear to be an annual seasonal occurrence. We are presently investigating additional monitoring parameters such as phosphorus and nitrogen.

We also hereby request a meeting with Regional Board Staff to discuss this incident.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Sincerely,

Joel V. Holt

Assistant Chief Plant Operator/Lab Supervisor

cc: Joe Jackson

MONTHLY EFFLUENT MONITORING REPORT

DISCHARGER: FALLBROOK PUBLIC UTILITY DISTRICT

CRWQCB ORDER NO. 2000-12

NPDES NO. CA0108031

REPORT FOR: MAY.

REPORT DUE: JUNE 30, 2001 REPORT FREQUENCY: MONTHLY

EXACT SAMPLE POINT: FILTERED EFFLUENT WELL SAMPLE TYPE: 24 Hr. COMPOSITE

SAMPLES COLLECTED BY: FPUD STAFF

SAMPLES ANALYZED BY: FPUD LABORATORY

SIGNED UNDER PENALTY OF PERJURY:

SUS	PEN	DED	SOL	IDS

		•	SUSPENDED	SOLIDS		1
		CONCENTRA		Į.		NG (LBS/DAY)
-: T			DAILY	30 DAY	7 DAY	DAILY
	AVERAGE	AVERAGE	MAXIMUM	AVERAGE	AVERAGE	MAXIMUM
	MG/L	MG/L	MG/L	LBS/DAY	LBS/DAY	LBS/DAY
REQT '	30	45	50	490	730	810
DATE	At a tra					
1-May-01	26.0	3.6	2.8	323.9	40.4	29.3
2-May-01	25.9	3.8	5.0	322.5	42.1	50.8
3-May-01	25.5	4.1	5.4	317.5	44.2	53.8
4-May-01	ľ	3.6	1.2	309.0	38.9	11.8
5-May-01	1	3.6		318.7	38.9	
6-May-01		3.5	1	330.0	36.3	
7-May-01	l ,	3.6	3.6	318.8	36.7	38.0
8-May-01	1	4.4	6.8	317.0	44.4	67.5
9-May-01	1	5.6	11.0	318.1	56.7	112.3
10-May-01	-	5.4	4.6	316.5	54.7	44.1
11-May-01	1	5,6	1.8	314.2	55.7	16.7
11-May-01 12-May-01	1	5.6		320.3	55.7	
	1	15.6	66.0	341.4	161.0	687.7
13-May-01 14-May-01		16.5	8.8	335.0	169.7	90.0
-	1	15.9	3.4	324.8	164.3	35.2
15-May-01	1	14.7	3.8	110.0	152.0	38.0
16-May-01	1	14.6	3.6	88.5	151.3	40.1
17-May-0	1	14.8	3.2	76.7	153.8	32.0
18-May-0	- 1	14.3	11.0	80.0	148.6	117.0
19-May-0	· }	5.6		81.5	58.7	
20-May-0		5.3	6.6	81.0	55.1	68.1
21-May-0	L	5.8	6.6	75.8	61.0	70.8
22-May-0	1	12.7	45.0	93.3	134.2	477.4
23-May-0	1 .	13.1	6.0	94.2	137.8	61.3
24-May-0	1	17.2	28.0	103.9	179.5	282.4
25-May-0	1	18.4	20.0	106.5	192.0	1
26-May-0	1	18.4		109.2	192.0	,
27-May-0		17.6	2.6	106.2	185.8	36.9
28-May-0	i i	17.6	5.4	107.1	186.4	73.8
29-May-0		8.7	1.6	106.3	94.2	16.7
30-May-0	•		5.2	107.5	93.4	57.1
31-May-(8.6	1.2	75.8	36.3	11.8
MIN.	7.1	3.5	66.0	341.4	192.0	687.7
MAX	28.1	18.4	1	205.0	103.7	104.3
AVG.	17.3	9.9	10.0	0	0	0
VIOLATION	VS 0	0	1	1 3	1	•